

Add value. Inspire trust.

Boge (Shanghai) Compressor Co., Ltd. 299 Gaoji Road, Sijing Town, Songjiang District, Shanghai P.R. China

## ATTESTION OF CONFORMITY

Dear Sirs,

According to the new standards ISO 8573-1:2010; ISO 8573-2:2018 and ISO 8753-5:2001 were respectively used previously in the investigation of the compressors, the measurement about the total oil content (aerosols, liquids and vapours) in the outlet air stream of below series Oil Free Screw Air Compressor has been validated.

Based on these Oil Free Screw Air Compressor similar construction and working principle, as a type test, SO180W, SO101WF and SO430W were randomly selected for the test.

Product name	Series	Models
Oil Free Screw	SO180W;	SO61A; SO61W; SO76A; SO76W; SO101A;
Air Compressor	SO101WF;	SO101W;SO126A; SO126W; SO150A; SO150W;
	SO430W;	SO180A; SO180W; SO200A; SO200W; SO220A;
		SO220W; SO269A; SO269W; SO270A; SO270W;
		SO340A; SO340W; SO430A; SO430W; SO431A;
		SO431W; SO480W; SO500W; SO550W; SO600W;
		SO650W; SO61AF; SO61WF; SO76AF; SO76WF;
		SO101AF; SO101WF; SO126AF; SO126WF; SO150AF;
		SO150WF; SO180AF; SO180WF; SO200AF; SO200WF;
		SO220AF; SO220WF; SO269AF; SO269WF; SO270AF;
		SO270WF; SO340AF; SO340WF; SO430AF; SO430WF;
		SO431AF; SO431WF; SO480WF; SO500WF; SO550WF;
		SO600WF; SO650WF

HSBC Bank (China) Company Limited Shanghai Branch Account No. (RMB): 088303235011

Account No. (USD): 001622349055 Account No. (EUR): 001622349056 SWIFT Code: HSBCCNSH

Managing Director of Central Region: Mr. Jan Sun

Telephone: +86 21 6141 0123 Telefax: +86 21 6140 8600 www.tuv-sud.cn TÜV®

TÜV SÜD Certification and Testing (China) Co., Ltd Shanghai Branch 3-13F, No. 151 Heng Tong Road Shanghai 200 070 P.R. China

SUD TUV SUD



The referenced guidelines and standards are as below:

ISO 8573-1:2010 Contaminant and purity clauses

ISO 8573-2:2018: Test methods for aerosol oil content method B1 (full flow method)

ISO 8573-5:2001: Test methods for oil vapour and organic solvent content

The type test report in the following has covered the entire range of Oil Free Screw Air Compressor. The model under test is randomly selected at every series. The test has been validated at the outlet of the air compressor without any cooling or oil removal devices in between the compressor and measurement point.

It is to clarify that at the specified test condition the quality of air from the above compressors qualified to be in the category "Class 0" in terms of total oil content, as defined in the standard ISO 8573-1:2010.

A detailed report with all conditions of the tests and results is available upon request.

No. 112795.0125 Rev.00

Test project No.: 70.520.21.071.01-00

Date: August 6, 2021

TÜV SÜD Certification and Testing (China) Co., Ltd. Shanghai Branch TÜV SÜD Group

Engineer:

Liwei SUN

Technical Report checked:

Qin ZHANG

HSBC Bank (China) Company Limited Shanghai Branch

Account No. (RMB): 088303235011 Account No. (USD): 001622349055 Account No. (EUR): 001622349056 SWIFT Code: HSBCCNSH

Managing Director of Central Region: Mr. Jan Sun

Telephone: +86 21 6141 0123 Telefax: +86 21 6140 8600 www.tuv-sud.cn